

# Spare Parts

## Eye wash diffuser kit for STD-75G / STD-85G

Part No. 01 02 075 12989

Hughes recommend replacing eye wash diffusers every 6 months to ensure correct functionality of the unit throughout its lifetime.


### What's included in the kit:

- x10 3/8 inch BSP aerated diffusers
- x10 aerator dust covers with chain assembly



## Specifications

MATERIALS		
EYE WASH DIFFUSERS	Rubber seal Plastic diffuser body Stainless steel filter Chrome plated brass retaining ring	
DUST COVERS	Rubber	
CHAIN ASSEMBLY	Chrome plated brass	
COMPATIBLE WITH THE FOLLOWING MODELS	<i>Eyewashes:</i> STD-75G STD-75G(S)/P STD-85G STD-85G(S)/P STD-SD-75G(S)/P STD-SD-85G(S)/P	<i>Combination Showers:</i> EXP-18G(S)/75G EXP-18G(S)/85G EXP-SD-18G(S)/75G EXP-SD-18G(S)/85G EXP-63G(S) EXP-65G(S) EXP-SD-63G(S) EXP-SD-65G(S)



### Replacing the eye wash diffusers:

- Remove the existing diffusers in an anti-clockwise direction
- Clean any dust or debris from the area
- Fit the new diffusers, taking care not to overtighten. The chain assembly can be attached using the split ring.